(VBDW07,10,12,15,20) VALVE INSTALLATION INSTRUCTIONS



30" COILED WIRE
WATER PROOF CONNECTOR
FINISH GRADE/TOP SOIL
STATION ID TAG
12" COVERED VALVE BOX
VALVE TYPE:
BUCKNER BY STORM VBDW07,10,12,15,20
PVC SCH 80 NIPPLE
PVC SCH 40 ELL
PVC SCH 80 NIPPLE
(LENGTH AS REQUIRED)
BRICK (4 PL)
PCV SCH 80 NIPPLE (MIN. 2" EXTENDED FROM MAIN LINE), AND SCH 40 ELL
MAIN LINE
PVC SCH 40 TEE OF ELL
PVC SCH 40 MALE ADAPTER
PVC VALVE LINE
APPROX. 3" DEPTH OF 1/4" WASHED GRAVEL

NOTE:

1. FURNISH FITTINGS AND PIPING NOMINALLY SIZED IDENTICAL TO NOMINAL VALVE INLET SIZE.

502817